



Peristaltic Metering Pump



Series A1

| Page 2 | Table of Contents | FLEXFLO® A |
|---------|--|------------|
| 1.0 | Introduction | 4 |
| | 1.1 Available Models | 4 |
| | 1.2 What's in the Box | 4 |
| 2.0 | Engineering Specifications | 5 |
| 3.0 | Materials of Construction | 6 |
| | 3.1 Wetted Components | 6 |
| | 3.2 Non-Wetted Components | 6 |
| 4.0 | Features | 7 |
| | 4.1 Agency Listings | 7 |
| 5.0 | Installation | 8 |
| | 5.1 Mounting Location | 8 |
| | 5.2 Pump Dimensions | 8 |
| | 5.3 Wall Mounting | 9 |
| | 5.4 Installing Injection Fitting and Strainer | 9 |
| | 5.5 Power Connections | 10 |
| | 5.6 Input / Output Connections | 12 |
| | 5.7 M12 Connections | 12 |
| 6.0 | Touchpad Layout | 13 |
| 7.0 | Set-Up, Programming, and Inputs | 14 |
| | 7.1 Remote Start / Stop | 15 |
| | 7.2 Programming FVS (Flow Verification Sensor) | 16 |
| | 7.3 Pump Lockout | 17 |
| | 7.4 4-20ma Input | 18 |
| 8.0 | Pump Operation | 19 |
| | 8.1 Priming the Pump | 19 |
| | 8.2 Manual Speed/Flow Adjust | 20 |
| | 8.3 4-20ma Speed/Flow Control | 21 |
| 9.0 | Outputs | 22 |
| | 9.1 Motor ON | 22 |
| | 9.2 Relay (FVS and TFD) | 22 |
| | 9.3 4-20mA Output | 22 |
| 10.0 | Tube Failure Detection (TFD+) | 22 |
| | 10.1 Confirming Chemical Detection | 22 |
| 11.0 | Pump Maintenance | 23 |
| | 11.1 Routine Inspection and Maintenance | 23 |
| | 11.2 Cleaning and Lubricating the Pump | 23 |
| 12.0 | Tube Replacement | 24 |
| | 12.1 Provided Tool | 24 |
| | 12.2 Tube Removal | 24 |
| | 12.3 Tube Installation | 26 |
| 13.0 | Firmware Update | 28 |
| 14.0 | Replacement Parts List | 30 |
| 14.0 | 14.1 Exploded View | 30 |
| 15.0 | Accessories | 32 |
| 16.0 | Troubleshooting | 34 |
| 17.0 | Warranty | 35 |
| | A: ACRONYMS | 36 |
| | B: MODEL NUMBER MATRIX | 37 |
| | | 01 |

READ THE ENTIRE OPERATING MANUAL PRIOR TO INSTALLATION AND USE.



+1 (714) 893 - 8529



sales@blue-white.com



customerservice@blue-white.com



5300 Business Drive Huntington Beach, CA 92649 Page 4 FLEXFLO® A1

1.0 INTRODUCTION

Congratulations on purchasing Blue-White's FLEXFLO® Series A1 peristaltic metering pump (a peristaltic metering pump is a type of positive displacement pump used for pumping a variety of fluids).

The FLEXFLO® Series A1 peristaltic metering pump is pre-configured for the tubing that is shipped with it.


NOTE: For accurate calibration of pump tube, run the pump for one hour with new tube installed prior to calibration.

NOTE: The tubing has an identification number printed on the tube for easy re-ordering.

NOTE: The pump was pressure-tested at the factory with clean water before it was shipped, so there may be trace amounts of clean water in the pre-installed tube assembly.

1.1 Available Models

FLEXFLO® Model Number



1.2 What's in the Box

- •Blue-White FLEXFLO® Series A1 peristaltic metering pump
- Power Cord
- •Two (2) Tube assemblies (one installed, one spare)
- •Tube installation tool
- •Injection Valve and Foot Strainer.
- •Suction Tubing and Discharge Tubing (with "T" type tube connector)
- Mounting Hardware Kit / Rear Bracket
- Display Shield
- •Instruction Manual

See Accessory page for additional options (Suction / Discharge Tubing, M12 communications cables, Wall Mount Bracket.)

2.0 ENGINEERING SPECIFICATIONS

| Maximum Working Pressure | 100 psig (6.89 bar) |
|-----------------------------------|--|
| Maximum Fluid Temperature | 185 °F (85 °C) |
| Maximum Ambient Temperature | 14 °F to 115 °F/ -10 °C to 46 °C |
| Maximum Viscosity | 5,000 Centipoise |
| Maximum Suction Lift | 30 ft. Water at sea level (14.7 atm psi) |
| | 115V60Hz 1 PH (0.6A max.) |
| | 220V50Hz 1 PH (0.3A max.) |
| Operating Voltage | 230V60Hz 1 PH (0.3A max.) |
| | 230V50Hz 1 PH (0.3A max.) |
| | 240V50Hz 1 PH (0.3A max.) |
| | 115V60Hz = NEMA 5/15 (USA) |
| | 230V60Hz = NEMA 6/15 (USA) |
| Power Cord Options | 220V50Hz = CEE 7/VII (EU) |
| | 240V50Hz = AS 3112 (Australia/New Zealand) |
| | 230V50Hz = BS 1363/A (UK) |
| Signal Connectors | M12 - 5 pin (IP67 rated connectors on "V" models) |
| Motor | Brushless DC, 50W |
| Duty Cycle | Continuous |
| Motor Speed Adjustment Resolution | 2,000 : 1 (0.05 - 100%) Max rpm = 65 rpm |
| Maximum Overall Dimensions | 7.25" W x 9" H x 10" D (18.5 W x 22.9 H x 25.2 D cm) |
| Product Weight | 6 lb. (2.7 Kg) |
| Approximate Shipping Weight | 13 lb. (5.9 Kg) |
| Approximate Shipping Dimensions | 10.5" W x 13.75" H x 11" D (26.7 W x 35 H x 28 D cm) |
| Enclosure | NEMA 4X (IP66), Valox® (PBT) & PA12 |
| RoHS Compliant | Yes |
| Standards | cETLus, CE |
| | |

^{1.} Refer to individual tube pressure and temperature ratings.

Page 6 FLEXFLO® A1

3.0 MATERIALS OF CONSTRUCTION

3.1 Wetted Components

Pump Tube Assembly

Tubing Flex-A-Prene®, Flex-A-Thane®, Flex-A-Chem®

Adapter Fittings PVDF (1/4" x 3/8" Tubing Connection, or 1/2" MNPT)

Injection / Back-Flow Check Valve

Body & Insert PVDF

Check Ball Ceramic

Spring Hastelloy C-276

Ball Seat O-Ring TFE/P

Static Seal O-Ring FKM

Ancillary Items Provided

Suction Tubing 3/8" OD x 1/4" ID x 5' Clear PVC

Discharge Tubing 3/8" OD x 1/4" ID x 5' Polyethylene (LLDPE)

Suction Strainer Polypropylene

Weight Ceramic

3.2 Non-Wetted Components

| Enclosure Valox® (P | PT) |
|---------------------|-----|
|---------------------|-----|

Pump Head Valox® (PBT)

Polycarbonate

Pump Head Cover

Permanently lubricated sealed motor shaft support ball

bearing.

Cover Screws Stainless steel, polypropylene cap

Roller Assembly

Rotor Valox® (PBT)

Rollers Nylon

Roller Bearings Bronze

TFD System Sensor Hastelloy C-276

Power Cord 3 conductor, SJTW-A water-resistant

Tube Installation Tool GF nylon

Mounting Brackets and Hardware 316 stainless steel screws

GF nylon bracket

4.0 FEATURES

- > Tube Failure Detection (TFD+) senses tube failure and shuts off the pump. No false triggering.
- > Heavy duty display shield protects pump controls.
- > Remote Start/Stop one non-powered dry contact closure.
- Compatible with Blue-White Flow Verification Sensor (FVS) system.
- Outputs: 4-20mA ("V" Model), 250V/3A (TFD or FVS) relay, solid state relay "motor on" (0-60VDC sinking)
- > Self-priming cannot vapor lock or lose prime.
- > Speed Control: Manual Speed Adjust and Scalable 4-20ma Input ("V" model)

4.1 Agency Listings



This pump is ETL listed to conforms to the following: UL Standard 778 as a motor operated water pump. CSA Standard C22.2 as process control equipment.



This pump complies to the Machinery Directive 2006/42/EC, BS, EN 60204-1, Low Voltage Directive 2014/35/EU BS EN 61010-1, EMC Directive 2014/30/EU, BS EN 50081-1/BS EN 50082-1.

| Symbol | Description |
|--------|---------------------------------------|
| *** | Warning (Risk of electric shock) |
| | Caution (Refer to the user's guide) |
| | Ground, Protective Conductor Terminal |

ENCLOSURE RATING

NEMA 4X Constructed for either indoor or outdoor use to provide a degree of protection to personnel against incidental contact with enclosed equipment; to provide a degree of protection against falling dirt, rain, sleet, snow, windblown dust, splashing water, and hose-directed water; and that will be undamaged by external formation of ice on enclosure.

IP66 No ingress of dust; complete protection against contact. Water projected in powerful jets against enclosure from any direction shall have no harmful effects.

Page 8 FLEXFLO® A1

5.0 INSTALLATION



The pump should be serviced by qualified persons only. If equipment is used in a manner not specified in this manual, the protection provided by the equipment may be impaired.



Always wear protective clothing, face shield, safety glasses and gloves when working on or near your metering pump. Additional precautions should be taken depending on solution being pumped. Refer to MSDS precautions from your solution supplier.



All diagrams are strictly for guideline purposes only. Always consult an expert before installing metering pump on specialized systems. Metering pump should be serviced by qualified persons only.



Check system pressure and piping/tubing pressure limits before installing.



The pump should be supplied by an isolating transformer or RCD (operating current less or equal 30 mA).

5.1 Mounting Location

- 1. Choose an area located near the chemical supply tank, chemical injection point, and electrical supply. Also, choose an area where the pump can be easily serviced.
- 2. Finding a secure surface and using the provided mounting hardware, mount the pump close to the injection point. Keep the inlet (suction) and outlet (discharge) tubing as short as possible. Longer discharge tubing increases back pressure at pump head.

NOTE: Mounting the pump lower than the chemical container will gravity-feed chemical into it. This "flooded suction" installation may minimize output variation by eliminating suction lift, and minimizing air and gasses entering the pump due to off-gassing and suction line leaks. A shut-off valve, pinch-clamp, or other means to halt gravity-feed to the pump must be installed during servicing.


NOTE: Install a back flow prevention check valve at the discharge side of the pump to prevent the system fluid from flowing back through pump during tube replacement or during tube leak.


NOTE: It is recommended to have a pressure relief valve at the discharge side of the of pump to prevent premature wear and damage to the pump tube, in the event that the discharge line becomes blocked.

NOTE: The pump does not require back pressure. Keep the discharge pressure as low as possible to maximize the tube life.

5.2 Pump Dimensions


| Dim | Inch | cm | Dim | Inch | cm |
|-----|-------|-------|-----|-------|-------|
| Α | 9.46" | 24.02 | D | 7.18" | 18.23 |
| В | 9.92" | 25.19 | E | 1.5" | 3.81 |
| С | 7.18" | 18.23 | | | |






5.3 Wall Mounting

1. Using #10 self-tapping screws, mount the bracket to a secure wall that is located where it can be easily serviced.







Wall Mount Bracket (Side View)


Mounted Pump (Front View)

Note: If mounting bracket to shelf, table, or floor, we recommend using mounting holes on bracket feet and using hardware appropriate for base surface. See Accessories for Wall Shelf options.

2. Lower the pump so that the tab on the wall mount is inserted into the slot located on the back of the pump. The pump will now be secured to the wall mount bracket. To release, pull tab forward and lift pump.







Wall Mount (Side View)

Mounted Pump

Page 10 FLEXFLO® A1

5.4 Installing Injection Fitting and Strainer



Proper eye and skin protection must be worn when installing and servicing the pump.


Assemble the injection fitting and strainer per the figures below.


NOTE: Install upward for best results.

NOTE: The injection nose may be trimmed (removed) when injecting into a small pipe.

INJECTION FITTING AND STRAINER FOR 1/4" (0.64 CM) I.D. CONNECTION END MODELS

Discharge Injection Fitting / Check Valve Suction Tubing and Strainer Pipe Tee Install upward for best results.





5.5 POWER CONNECTIONS



Risk of electric shock – cord connected models are supplied with a grounding conductor and grounding-type attachment plug. To reduce risk of electric shock, be certain that it is connected only to a properly grounded, grounding-type receptacle.



Electrical connections and grounding (earthing) must conform to local wiring codes.



Ensure to connect the pump to the proper supply voltage. Using the incorrect voltage will damage the pump and may result in injury. The voltage requirements is printed on the pump serial label.

- > Use the voltage for which the power cord is rated.
- > Power Cord receptacle located on bottom of pump.
- > To prevent electronic noise interference, electronic signal wires and AC power wires must be kept separate. Do not bundle these cables together or run within the same conduit.
- > When there is a power interruption, the pump will restart(resume) in the same state it was in when the power was lost.
- POWER: 115V60Hz (0.6A max.), 220V50Hz (0.3A max.), 230V60Hz (0.3A max.), 230V50Hz (0.3A max.), 240V50Hz (0.3A max.)

NOTE: When in doubt regarding your electrical installation, contact a licensed electrician.




Page 12 FLEXFLO® A1

5.6 IO Connection



Risk of electric shock - All wiring must be insulated and rated 60V minimum.




Pump (Right Side Panel)

| Item Number | Item |
|-------------|--|
| 1 | USB-C Connector |
| 2 | M12 Input Connector 1 (Included with A1V ONLY) |
| 3 | M12 Input Connector 2 |
| 4 | M12 Output Connector |

M12 connectors not included with product.

Blue-White Industries requires any A-Type M12 connector with 5 position female sockets Shielded cable should be used for all signal wires FLEXFLO® A1 Page 13

5.7 M12 Connector



M12 Connector I/O 1 - Included with A1V ONLY

| PIN | Function | Specifications | Reference |
|-----|-------------------|-------------------------------------|--------------|
| P1 | 4-20mA Input (+) | 120 Ohm Impedance, Non powered loop | (+) Positive |
| P2 | 4-20mA Input (-) | 120 Ohm Impedance, Non powered loop | (-) Negative |
| P3 | 4-20mA Output (+) | 600 Ohm Max Load | (+) Positive |
| P4 | 4-20mA Output (+) | DC Ground (0 VDC) | (-) Negative |
| P5 | | Not Used | |

M12 Connector I/O 2


| PIN | Function | Specifications | Reference |
|-----|---------------------|--|--|
| P1 | Remote Start / Stop | N.O. Dry Contact Closure (Do not add voltage) | Green Light = Normally Open Red Light = Normally Closed |
| P2 | Ground | DC Ground | 0 VDC |
| P3 | FVS (+) | 15 VDC @ 60 mA | (+) Positive |
| P4 | FVS (-) | DC Ground (0 VDC) | (-) Negative |
| P5 | FVS (Signal) | Input Signal | Input for FVS Signal |

M12 Connector I/O 3

| PIN | Function | Specifications |
|-----|------------------|--|
| P1 | Motor On Out (+) | 0-60VDC Sinking output (+) Solid State Contact Closure |
| P2 | Motor On Out (-) | 0-60VDC Sinking Output (-) Solid State Contact Closure |
| Р3 | N.O. | Relay Out, N.O. Contact 3 Amp @ 250 VAC |
| P4 | COM | Relay Out, COM Contact |
| P5 | N.C. | Relay Out, N.C. Contact 3 Amp @ 250 VAC |

Page 14 FLEXFLO® A1


6.0 TOUCHPAD LAYOUT



| Item Number | ltem |
|-------------|------------------------------------|
| 1 | LED/LCD Readout |
| 2 | Rate Display Key |
| 3 | Flow Verification Sensor (FVS) Key |
| 4 | Remote Start/Stop Key |
| 5 | Lock-Out Key |
| 6 | Prime Key |
| 7 | Start & Stop Key |
| 8 | Down Key |
| 9 | Up Key |
| 10 | Manual Speed Adjust |
| 11 | 4-20mA |

7.0 SET-UP AND PROGRAMMING

7.1 Remote Start/Stop




| Item Number | Directions for Normally Open Operation |
|-------------|---|
| 1 | Confirm that pump is in the OFF position |
| 2 | Press Remote Start/Stop button to activate |
| 3 | Light will turn Green for "Normally Open" Operation |
| 4 | To put pump is Ready state, press Start/Stop button |
| 5 | Display will show "SIG" when waiting for contact closure signal |
| 6 | Display will show pump speed (or RPM, 4-20ma) when signal is closed |

| Item Number | Directions for Normally Closed Operation |
|-------------|--|
| 1 | Confirm that pump is in the OFF position, and Remote Start/Stop light is off |
| 2 | Press and hold Remote Start/Stop button for 5-7 seconds |
| 3 | Light will turn Red for "Normally Closed" Operation |
| 4 | To put pump is Ready state, press Start/Stop button |
| 5 | Display will show "SIG" when waiting for contact closure to Open |
| 6 | Display will show pump speed (or RPM, 4-20mA) when signal is Open |

Page 16 FLEXFLO® A1

7.2 Programming FVS (Flow Verification Sensor)

Flow Verification System (FVS) uses a pulse signal from flow meter/sensor. When the FVS feature is activated, if running pump does not receive signal/pulse in the programmed delay time, the pump will stop and activate Alarm Output Relay. Display will read "FuS". (Contact Blue-White for FVS sensor options.)




| Item Number | Directions for Programming FVS | |
|-------------|--|--|
| 1 | Confirm that pump is in the OFF position | |
| 2 | Press and hold FVS button (5-7 seconds) | |
| 3 | Toggle up/down arrow to set Delay Time | |
| 4 | Press and hold FVS button (5-7 seconds) | |

Activate by pressing FVS button once. Light On indicates activation. Press again to de-activate. NOTE: Alarm Delay Time range 1-20 seconds

7.3 Pump Lockout

Pump Lockout feature allows the user to "lock out" the ability to change pump controls, such as Pump Speed, Prime, FVS, Remote Start/Stop, Manual/4-20ma Modes. User will still be able to start and stop the pump.




| Item Number | Directions |
|-------------|---|
| 1 | Pump can be running or in the OFF position |
| 2 | Press and hold Lockout button (5-7 seconds) |
| 3 | Light will activate |
| 4 | To de-activate, press and hold Lockout button (5-7 seconds) |

Page 18 FLEXFLO® A1

7.4 4-20mA Input (With "V" Model Only)


Selecting 4-20mA input mode



Directions

- 1 Confirm that pump is in the OFF position
- 2 Press 4-20mA Input button

Programming 4-20mA input mode




Directions

- 1 Confirm that pump is in the OFF position.
- 2 Press and hold 4-20mA Input button.
 - MIN mA light will illuminate. Use arrow
- 3 keys to toggle min mA value for the pump to operate at
- 4 Press 4-20mA Input button for MIN % Speed light to illuminate
- Use arrow keys to toggle MIN % Speed value for the pump to operate.
- 6 Press 4-20mA Input button for MAX mA light to illuminate.
- 7 Use arrow keys to toggle MAX mA value for the pump to operate.
- 8 Press 4-20mA Input button for MAX % Speed light to illuminate.
- 9 Use arrow keys to toggle MAX % Speed value for the pump to operate.
- Press and hold 4-20mA Input button to exit programming mode.

FLEXFLO® A1 Page 19

8.0 PUMP OPERATION





| Item Number | Directions |
|-------------|--|
| 1 | Pump can be running or in the OFF position |
| 2 | Press Prime button |
| 3 | Pumps will run at 100% speed and Display will count down from 60 seconds |
| 4 | Press Start/Stop button at any time to Stop pump |


Need help calibrating your pump? Click on ... or scan the QR code.



Page 20 FLEXFLO® A1

8.2 Manual Speed/Flow Adjust


Pump speed can be adjusted manually using "Manual Adjust" Run Mode.



| Item Number | Directions |
|-------------|--|
| 1 | Confirm that pump is in the OFF position |
| 2 | Press "Manual Adjust" button. Local light will activate. |
| 3 | Press Start/Stop button. |
| 4 | Adjust pump speed using up and down arrows |

8.3 4-20 Input Speed/Flow Control (With "V" Model Only)

Pump speed can be adjusted remotely using "4-20ma Input" Run Mode.



| Item Number | Directions |
|-------------|---|
| 1 | Confirm that pump is in the OFF position |
| 2 | Press "4-20ma Input" button. Remote light will activate. |
| 3 | Press Start/Stop button. |
| 4 | Pump speed will be adjusted by 4-20ma input signal |
| 5 | Adjust up and down arrows to display % speed, RPM, or 4-20mA input signal |

Page 22 FLEXFLO® A1

9.0 OUTPUTS

MOTOR ON - Active when motor is running in Manual or 4-20ma Mode.

RELAY OUTPUT - Active when either TFD or FVS has triggered. Stop pump to reset.

4-20 mA OUTPUT - Non-scalable full scale output proportional to pump speed.


10.0 TUBE FAILURE DETECTION (TFD+)

The pump is equipped with a Enhanced Tube Failure Detection (TFD+) system, which is designed to stop the pump and provide an output alarm in the event the pump tube should rupture, and a chemical enters the pump head.

This TFD+ system can detect the presence of many chemicals, including sodium hypochlorite (chlorine), hydrochloric (muriatic) acid, sodium hydroxide, oils based polymers, water based polyers, and many others.

NOTE: If the system has detected a chemical, the pump tube must be replaced, and the pump head and roller assembly must be thoroughly cleaned. Failure to clean the roller assembly will void the warranty.

NOTE: If the TFD+ alarm is triggered, the pump will stop, and close an alarm output. See M12 Connection details to wire this alarm.



10.1 Confirming Chemical Detection

To determine if a chemical will be detected by the system:

- 1. Remove the pump head cover, and the pump tube and roller assembly.
- 2. Place a small amount of chemical in the bottom of the pump head that is enough to cover the sensor.
- 3. Reinstall only the pump head cover.
- 4. Turn on the pump by pressing the START button.

NOTE: If the TFD+ system **detects** a chemical, the pump will stop after a two-second confirmation period.

NOTE: If the TFD+ system **does not detect** a chemical, the pump will continue to operate after the confirmation period.

- 5. Carefully clean the chemical out of the pump head. Ensure to remove all the chemical traces from the sensor.
- 6. Reinstall the roller assembly and tubing.
- 7. Reinstall the pump head cover.
- 8. Press the START button to clear the alarm condition.
- 9. Restart the pump.

FLEXFLO® A1 Page 23

11.0 PUMP MAINTENANCE



Always wear protective clothing, face shield, safety glasses and gloves when working on or near your metering pump. Additional precautions should be taken depending on the solution being pumped. Refer to MSDS precautions from your solution supplier.

11.1 Routine Inspection and Maintenance

The pump requires minimal maintenance. However, the pump and all the accessories should be checked weekly, especially when pumping chemicals. Inspect all the components for signs of leaking, swelling, cracking, discoloration, or corrosion. Immediately replace worn out or damaged components.

Cracking, crazing, or discoloration during the first week of operation are signs of a severe chemical attack. If this occurs, perform the following steps:

- 1. Immediately remove the chemical from the pump.
- 2. Determine which parts are being attacked.
- 3. Replace the damaged parts with parts that have been manufactured using more suitable materials.
- 4. After servicing, operate the pump to verify normal operation.

NOTE: The manufacturer does not assume responsibility for damage to a pump that has been caused by a chemical attack.

11.2 Cleaning and Lubricating the Pump

- > The pump will require occasional cleaning, and it will depend on the severity of service.
- > When changing the pump tube assembly, the pump head chamber, the roller assembly, and the pump head cover should be wiped of any dirt and debris.
- > Clean the motor shaft with a clean towel, and then apply a small amount of grease to the shaft. This will help prevent the rotor from sticking to the motor shaft.
- > Periodically, or when necessary, grease the pump head cover bearing. Apply a small amount of grease (Aeroshell aviation grease #5 or equivalent).
- > 100% silicone lubrication may be used on the roller assembly.
- > Periodically clean the injection fitting /check valve assembly, especially since injecting fluids, like sodium hypochlorite, can calcify. These lime deposits and other buildups can clog the fitting, increase back pressure, and interfere with the check valve operation.
- > Periodically clean the suction strainer.

Not Sure ... Watch Instructional Video

Click on ... or scan QR code.



12.0 TUBE REPLACEMENT



Prior to service, pump clean water through the pump and suction / discharge line to remove any chemical.



Always wear protective clothing, face shield, safety glasses and gloves when working on or near your metering pump. Additional precautions should be taken depending on solution being pumped. Refer to MSDS precautions from your solution supplier.



Use the provided Tube Installation Tool to leverage tubing into the pump head. **Do not use your fingers.**



Use extreme caution when replacing the pump tube. Do not place your fingers near the rollers.

The pump tube assembly will eventually become non-operational if it is not regularly inspected and replaced. The tube life is affected by many factors, such as the type of chemical being pumped, the amount of back pressure, the motor revolutions per minute (RPM), and temperature.

12.1 Provided Tool



Tube Installation Tool 90002-278

12.2 Tube Removal




Safety first. Remove the pressure. Relieve (remove) the system pressure on the discharge and suction side of the pump. Failure to do so will cause the solution to squirt when disconnecting the tube connections.

- 1. Disconnect the system plumbing from the pump tube adapters.
- 2. Press the Start/Stop key to stop the pump.
- Remove the three black thumb screws from the front of the pump head cover by unscrewing counterclockwise. Remove the pump head cover by pulling straight out.




- 4. **Set the motor speed to 10%.** Press the Start/Stop key to start the pump.
- 5. With the pump running, pull the inlet (suction) fitting out of the pump head. Guide the tube counterclockwise away from the rollers. Pull the outlet (discharge)fitting out of the pump head.





6. Press the Start/Stop key to stop the pump.



Page 26 FLEXFLO® A1


12.3 Tube Installation

NOTE: Thoroughly clean the pump head and rotor. The rotor can be removed by pulling it straight out. After cleaning, push the rotor back on the shaft.

- 1. **Set the motor speed to 10%.** Press the Start/Stop key to start the pump.
- 2. Insert the inlet (suction) side of the pump tube fitting into the lower retaining slot of the pump head. Carefully guide the pump tube into the pump head.



3. Stretch the tube slightly and insert the outlet (discharge) fitting into the upper retaining slot of the pump head. Pull the outlet fitting out of the pump head.





4. Place the clear cover onto the pump head. Secure the cover with the provided three thumb screws. The pump is now ready for operation.



Not Sure ... Watch Instructional Video


Click on ... or scan QR code.



Updating The Firmware 13.0


REQUIREMENTS: Download & Install the A1 Progammer file by visiting the Firmware Update section of the A1 product page at www.blue-white.com as well as download the Firmware Update File.

- 1. Connect the Pump to a computer via USB-A / USB-C cable




Click on Connect 5.

Watch this Video for further assistance.




6. Select "Load Hex File"




7. Select ".HEX" file



8. Click on "Erase-Program-Verify"



- 9. Once Hex file is loaded successfully
- 10. Click on "Disconnect". Your firmware has now been updated.



14.0 REPLACEMENT PARTS LIST


| Item | Description | Part | Quantity |
|------|---|--|----------|
| 1 | Spacer, back | 90011-014 | 1 |
| | Roller assembly complete (rotor) A1-1T, A1-2T, A1-3T, A1-7T | 71000-350 | |
| 2 | Roller assembly complete (rotor) A1-4T, A1-6T | 71000-159 | 1 |
| | Roller assembly complete (rotor) A1-8T | 71000-255 | |
| 3 | Tube assembly, 1/4" OD, Flex-A-Thane® Tube assembly, 7/16" OD, Flex-A-Thane® Tube assembly, 1/4" OD, Flex-A-Prene® Tube assembly, 3/8" OD, Flex-A-Prene® Tube assembly, 7/16" OD, Flex-A-Prene® Tube assembly, 7/16" OD, Flex-A-Chem® | A1-1* A1-3* A1-4* A1-6* A1-7* A1-8* | 2 |
| 4 | Pump head cover, Acrylic | A1-SXX-C | 1 |
| 5 | Thumb screw with 9/64" key drive, maximum torque 6-8 in. lbs. | 90011-160 | 3 |
| 6 | Tube nut, compression, for 3/8" tubing | C-330-6 | 2 |
| 7 | Cover A1 Polycarbonate (not pictured) | 90002-684 | 1 |

NOTES:

^{* -} Designate "T" Tube Compression, or "M" 1/2" MNPT connection types when ordering.

FLEXFLO® A1 Page 31

14.1 EXPLODED VIEW



Page 32 FLEXFLO® A1

15.0 ACCESSORIES

The following accessories are available for the A1 FLEXFLO® Peristaltic Metering Pump. Please visit Bluewhite.com for more information. All accessories are sold separately.



KIT-M12

Kit contains: Two M12 cables. 10 foot length.

KIT-M12-2-5 5 foot length. KIT-M12-2-15 15 foot length. KIT-M12-2-30 30 foot length.

| KIT-M12 WIRING INSTRUCTIONS | | |
|-----------------------------|-------|------------|
| DIAGRAM | PIN# | WIRE COLOR |
| | PIN 1 | BROWN |
| P2 P1 | PIN 2 | WHITE |
| P5 | PIN 3 | BLUE |
| P3 P4 | PIN 4 | BLACK |
| | PIN 5 | GRAY |

NOTE: THIS DIAGRAM IS FOR THE PUMP'S M12 PORT



KIT-M12-3

Kit contains: Three M12 cables. 10 foot length.

KIT-M12-3-5 5 foot length. KIT-M12-3-15 15 foot length. KIT-M12-3-30 30 foot length.



CABLE-UAC

Kit contains: One 3' USB-A to USB-C cable.



POWER CORDS - DETACHABLE

90010-663 115V/60Hz NEMA 5/15 90010-664 220V/50Hz CEE 7/V11 90010-665 230V/50Hz BS 1363/A 90010-666 240V/50Hz AS 3112 90010-696 230V/60Hz NEMA 6/15 90010-821 115V/60Hz NEMA 5/15 (Lockable)



SUCTION AND DISCHARGE TUBING

| C-334-6 | Tubing, Suction, clear PVC 3/8" O.D. x 5' length |
|-------------|--|
| C-334-6-10 | Tubing, Suction, clear PVC 3/8" O.D. x 10' length |
| C-334-6-100 | Tubing, Suction, clear PVC 3/8" O.D. x 100' length |
| C-335-6 | Tubing, Discharge, opaque PE 3/8" O.D. x 5' length |
| C-335-6-10 | Tubing, Discharge, opaque PE 3/8" O.D. x 10' length |
| C-335-6-100 | Tubing, Discharge, opaque PE 3/8" O.D. x 100' length |

NOTE: All Accessories are sold separately



KIT-S07

Kit contains: One 7 gallon tank,, One foot valve and strainer and One mounting bracket with screws



KIT-S15

Kit contains: One 15 gallon tank, One foot valve and strainer and One mounting bracket with screws



KIT-S30

Kit contains: One 30 gallon tank, One foot valve and strainer and One mounting bracket with screws



KIT-PSM

Kit contains: One HDPE Bracket, (4) 3/8" x 2-3/4" long dia anchor bolts.

Page 34 FLEXFLO® A1

16.0 TROUBLESHOOTING

| Error Code | Explanation | Troubleshooting |
|------------|-------------------------------------|---|
| E01 | Motor Over Current | Check that tube is installed correctly |
| E02 | Over Voltage | Check power supply output voltage |
| E03 | Under Voltage | Check power supply output voltage |
| E04 | Temperature exceeds 75°C at control | Check ambient conditions, restart pump once cooled to ambient temperature |
| E05 | Inverter Error | Contact Blue-White (714) 893-8529 customerservice@blue-white.com |
| E06 | No Motor Connection | Contact Blue-White (714) 893-8529 customerservice@blue-white.com |
| E08 | Motor Stall | Check that tube is properly installed |
| E10 | Capacitor bank charging error | Contact Blue-White (714) 893-8529 customerservice@blue-white.com |
| E17 | Communication error at display | Contact Blue-White (714) 893-8529 customerservice@blue-white.com |

17.0 WARRANTY

17.1 LIMITED WARRANTY

Your new FLEXFLO pump is a quality product and is warrantied for 24 months from date of purchase (proof of purchase is required). The pump will be repaired or replaced at our discretion. Failure must have occurred due to defect in material or workmanship and not as a result of operation of the product other than in normal operation as defined in the pump manual. Warranty status is determined by the pump's serial label and the sales invoice or receipt. The serial label must be on the pump and legible. The warranty status of the pump will be verified by Blue-White or a factory authorized service center.

Pump Head and roller assembly is warrantied against damage from chemical attack when proper TFD+ (Tube Failure Detection) system instructions and maintenance procedures are followed.

17.2 WHAT IS NOT COVERED

- Pump Tube Assemblies and rubber components They are perishable and require periodic replacement.
- Pump removal, or re-installation, and any related labor charge.
- Freight to the factory, or a certified service center.
- Pumps that have been tampered with, or in pieces.
- Damage to the pump that results from misuse, carelessness such as chemical spills on the enclosure, abuse, lack of maintenance, or alteration which is out of our control.
- Pumps damaged by faulty wiring, power surges or acts of nature.

17.3 PROCEDURE FOR IN WARRANTY REPAIR

Contact the factory to obtain a RMA (Return Material Authorization) number. Carefully pack the pump to be repaired. It is recommended to include foot strainer and injection/check valve fitting since these devices may be clogged and part of the problem. Please enclose a brief description of the problem as well as the original invoice or sales receipt, or copy showing the date of purchase. Prepay all shipping costs. COD shipments will not be accepted. Warranty service must be performed by the factory or an authorized service center. Damage caused by improper packaging is the responsibility of the sender. When In-Warranty repair or replacement is completed, the factory pays for return shipping to the dealer or customer.

17.4 PRODUCT USE WARNING

Blue-White products are manufactured to meet the highest quality standards in the industry. Each product instruction manual includes a description of the associated product warranty and provides the user with important safety information. Purchasers, installers, and operators of Blue-White products should take the time to inform themselves about the safe operation of these products. In addition, Customers are expected to do their own due diligence regarding which products and materials are best suited for their intended applications. Blue-White is pleased to assist in this effort but does not guarantee the suitability of any particular product for any specific application as Blue-White does not have the same degree of familiarity with the application that the customer/end user has. While Blue-White will honor all of its product warranties according to their terms and conditions, Blue-White shall only be obligated to repair or replace its defective parts or products in accordance with the associated product warranties. BLUE-WHITE SHALL NOT BE LIABLE EITHER IN TORT OR IN CONTRACT FOR ANY LOSS OR DAMAGE WHETHER DIRECT, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL, ARISING OUT OF OR RELATED TO THE FAILURE OF ANY OF ITS PARTS OR PRODUCTS OR OF THEIR NONSUITABILITY FOR A GIVEN PURPOSE OR APPLICATION.

17.5 CHEMICAL RESISTANCE WARNING

Blue-White offers a wide variety of wetted parts. Purchasers, installers, and operators of Blue-White products must be well informed and aware of the precautions to be taken when injecting or measuring various chemicals, especially those considered to be irritants, contaminants or hazardous. Customers are expected to do their own due diligence regarding which products and materials are best suited for their applications, particularly as it may relate to the potential effects of certain chemicals on Blue-White products and the potential for adverse chemical interactions. Blue-White tests its products with water only. The chemical resistance information included in this instruction manual was supplied to Blue-White by reputable sources, but Blue-White is not able to vouch for the accuracy or completeness thereof. While Blue-White will honor all of its product warranties according to their terms and conditions, Blue-White shall only be obligated to repair or replace its defective parts or products in accordance with the associated product warranties. BLUE-WHITE SHALL NOT BE LIABLE EITHER IN TORT OR IN CONTRACT FOR ANY LOSS OR DAMAGE, WHETHER DIRECT, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL, ARISING OUT OF OR RELATED TO THE USE OF CHEMICALS IN CONNECTION WITH ANY BLUE-WHITE PRODUCTS.

Page 36 FLEXFLO® A1

APPENDIX A: ACRONYMS

°C Celsius
°F Fahrenheit
AC Alternating current
bar Unit of pressure
CIP Clean-in-place
cm Centimeters
COD Cash on Delivery

D Depth

DC Direct current

EEE Electrical and electronic equipment

EP Ethylene propylene

ETL Electrical Testing Labs/Intertek

EU European Union

FDA Food and Drug Administration

FKM Fluoroelastomer

FVS Flow Verification Sensor

GF Glass fiber
GPD Gallons per day
GPH Gallons per hour

H Height Hz Hertz

ID Inside diameter
IO Input/Output
Kg Kilogram
Ib. Pound

LLDPE Linear low-density polyethylene

LPH Liters per hour mA Milliampere min Minute mL Milliliters

MSDS Material Safety Data Sheet

N.C. Normally CloseN.O. Normally OpenNPT National Pipe Thread

NSF National Sanitation Foundation

OD Outside diameter P.N. Part Number

PBT Polybutylene Terephthalate

PE Polyethylene

PSI Pounds per Square Inch
PVC Polyvinyl chloride
PVDF Polyvinylidene fluoride

Residual-current device

Rev. Revision

RCD

RMA Return Material Authorization

RPM Revolutions per minute

SIP Steam-in-place SS Solid state

TFD+ Enhanced Tube Failure Detection
TFE/P Tetrafluoroethylene propylene
UL Underwriters Laboratories


US United States

V Volt W Watt W Width

WEEE Waste Electrical and Electronic Equipment

Model Number Matrix

FLEXFLO® Model Number



Page 38 FLEXFLO® A1

NOTES:

NOTES:



Users of electrical and electronic equipment (EEE) with the WEEE marking per Annex IV of the WEEE Directive must not dispose of end of life EEE as unsorted municipal waste, but use the collection framework available to them for the return, recycle, recovery of WEEE and minimize any potential effects of EEE on the environment and human health due to the presence of hazardous substances. The WEEE marking applies only to countries within the European Union (EU) and Norway. Appliances are labeled in accordance with European Directive 2002/96/EC.

Contact your local waste recovery agency for a Designated Collection Facility in your area.



5300 Business Drive Huntington Beach, CA 92649 USA

TEL: 714-893-8529 FAX: 714-894-9492

www.blue-white.com customerservice@blue-white.com

P.N. 80000-609 Rev 18 20231205